

IMPORTANT NOTICE

The **ECAP321** is designed for **VERTICAL** venting applications on **PVC** or **ABS Plastic Pipe ONLY**.

Although it can be used for HORIZONTAL venting applications by extending the pipe from the building structure per the furnace/boiler manufacturers installation instructions, and adding a 90 degree elbow in the Up position. Then install the ECAP321 on to the elbow.

The flue gases will exhaust in the down flow direction.

- Install with at least 10" clearance from roof line
- Installs with standard PVC Cement
- Fits 1.5", 2" and 3" PVC Pipe
- Can be used on both Intake and Exhaust
- Install Exhaust at least 10" above Intake



SEALED UNIT PARTS CO., INC.

2230 Landmark Place • Allenwood, NJ 08720 USA
(732) 223-6644 • Fax (732) 223-1617
www.supco.com • info@supco.com

IMPORTANT NOTICE

The **ECAP321** is designed for **VERTICAL** venting applications on **PVC** or **ABS Plastic Pipe ONLY**.

Although it can be used for HORIZONTAL venting applications by extending the pipe from the building structure per the furnace/boiler manufacturers installation instructions, and adding a 90 degree elbow in the Up position. Then install the ECAP321 on to the elbow.

The flue gases will exhaust in the down flow direction.

- Install with at least 10" clearance from roof line
- Installs with standard PVC Cement
- Fits 1.5", 2" and 3" PVC Pipe
- Can be used on both Intake and Exhaust
- Install Exhaust at least 10" above Intake



SEALED UNIT PARTS CO., INC.

2230 Landmark Place • Allenwood, NJ 08720 USA
(732) 223-6644 • Fax (732) 223-1617
www.supco.com • info@supco.com

IMPORTANT NOTICE

The **ECAP321** is designed for **VERTICAL** venting applications on **PVC** or **ABS Plastic Pipe ONLY**.

Although it can be used for HORIZONTAL venting applications by extending the pipe from the building structure per the furnace/boiler manufacturers installation instructions, and adding a 90 degree elbow in the Up position. Then install the ECAP321 on to the elbow.

The flue gases will exhaust in the down flow direction.

- Install with at least 10" clearance from roof line
- Installs with standard PVC Cement
- Fits 1.5", 2" and 3" PVC Pipe
- Can be used on both Intake and Exhaust
- Install Exhaust at least 10" above Intake



SEALED UNIT PARTS CO., INC.

2230 Landmark Place • Allenwood, NJ 08720 USA
(732) 223-6644 • Fax (732) 223-1617
www.supco.com • info@supco.com

IMPORTANT NOTICE

The **ECAP321** is designed for **VERTICAL** venting applications on **PVC** or **ABS Plastic Pipe ONLY**.

Although it can be used for HORIZONTAL venting applications by extending the pipe from the building structure per the furnace/boiler manufacturers installation instructions, and adding a 90 degree elbow in the Up position. Then install the ECAP321 on to the elbow.

The flue gases will exhaust in the down flow direction.

- Install with at least 10" clearance from roof line
- Installs with standard PVC Cement
- Fits 1.5", 2" and 3" PVC Pipe
- Can be used on both Intake and Exhaust
- Install Exhaust at least 10" above Intake



SEALED UNIT PARTS CO., INC.

2230 Landmark Place • Allenwood, NJ 08720 USA
(732) 223-6644 • Fax (732) 223-1617
www.supco.com • info@supco.com



For use on 3 sizes (1 1/2", 2" & 3")
for use on plastic vent pipes from
High Efficiency
furnace installations with maximum outlet
temperatures of 212 °F (100 °C)

Certification Requirements:

PRODUCTS

CLASS

3307-02

DRAFT EQUIPMENT Gas Vents

3307-82

DRAFT EQUIPMENT Gas Vents Certified to U.S. Standards

ECAP321

APPLICABLE REQUIREMENTS

ULC 5636

Standard for Venting Systems for Gas-Burning Appliances,
Categories II, III and IV

ANSI/UL 1738-2000

Standard for Venting Systems for Gas-Burning Appliances,
Categories II, III and IV

ANSI Z21.47/

Gas-Fired Central Furnaces CSA 2.3



R55-713

SEALED UNIT PARTS CO., INC.

2230 Landmark Place • Allenwood, NJ 08720 USA

(732) 223-6644 • Fax (732) 223-1617

www.supco.com • info@supco.com



For use on 3 sizes (1 1/2", 2" & 3")
for use on plastic vent pipes from
High Efficiency
furnace installations with maximum outlet
temperatures of 212 °F (100 °C)

Certification Requirements:

PRODUCTS

CLASS

3307-02

DRAFT EQUIPMENT Gas Vents

3307-82

DRAFT EQUIPMENT Gas Vents Certified to U.S. Standards

ECAP321

APPLICABLE REQUIREMENTS

ULC 5636

Standard for Venting Systems for Gas-Burning Appliances,
Categories II, III and IV

ANSI/UL 1738-2000

Standard for Venting Systems for Gas-Burning Appliances,
Categories II, III and IV

ANSI Z21.47/

Gas-Fired Central Furnaces CSA 2.3



R55-713

SEALED UNIT PARTS CO., INC.

2230 Landmark Place • Allenwood, NJ 08720 USA

(732) 223-6644 • Fax (732) 223-1617

www.supco.com • info@supco.com



For use on 3 sizes (1 1/2", 2" & 3")
for use on plastic vent pipes from
High Efficiency
furnace installations with maximum outlet
temperatures of 212 °F (100 °C)

Certification Requirements:

PRODUCTS

CLASS

3307-02

DRAFT EQUIPMENT Gas Vents

3307-82

DRAFT EQUIPMENT Gas Vents Certified to U.S. Standards

ECAP321

APPLICABLE REQUIREMENTS

ULC 5636

Standard for Venting Systems for Gas-Burning Appliances,
Categories II, III and IV

ANSI/UL 1738-2000

Standard for Venting Systems for Gas-Burning Appliances,
Categories II, III and IV

ANSI Z21.47/

Gas-Fired Central Furnaces CSA 2.3



R55-713

SEALED UNIT PARTS CO., INC.

2230 Landmark Place • Allenwood, NJ 08720 USA

(732) 223-6644 • Fax (732) 223-1617

www.supco.com • info@supco.com



For use on 3 sizes (1 1/2", 2" & 3")
for use on plastic vent pipes from
High Efficiency
furnace installations with maximum outlet
temperatures of 212 °F (100 °C)

Certification Requirements:

PRODUCTS

CLASS

3307-02

DRAFT EQUIPMENT Gas Vents

3307-82

DRAFT EQUIPMENT Gas Vents Certified to U.S. Standards

ECAP321

APPLICABLE REQUIREMENTS

ULC 5636

Standard for Venting Systems for Gas-Burning Appliances,
Categories II, III and IV

ANSI/UL 1738-2000

Standard for Venting Systems for Gas-Burning Appliances,
Categories II, III and IV

ANSI Z21.47/

Gas-Fired Central Furnaces CSA 2.3



R55-713

SEALED UNIT PARTS CO., INC.

2230 Landmark Place • Allenwood, NJ 08720 USA

(732) 223-6644 • Fax (732) 223-1617

www.supco.com • info@supco.com